

Message

From: pizarro, luis [/O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=82DDA7A144D8467090A578BF730493F7-LPIZARRO]
Sent: 6/22/2017 5:56:26 PM
To: McDougal, Jason S [Jason.S.McDougal@wv.gov]
Subject: RE: Momentive Water Treatment Upgrade

Jake:

Here is what I got from one of our PM's - Liquid PCB standards are at 40 CFR Section 761.79(b) – basically, the standard for unrestricted use is less than or equal to 0.5 ug/L total PCBs. Water with less than 3 ug/L PCBs can be discharged to a stream or POTW

Luis A. Pizarro
Associate Director
Office of Remediation, LCD
US EPA Region 3
215 814 3444

From: McDougal, Jason S [mailto:Jason.S.McDougal@wv.gov]
Sent: Wednesday, June 21, 2017 5:34 PM
To: pizarro, luis <pizarro.luis@epa.gov>
Subject: Re: Momentive Water Treatment Upgrade

Thanks. Yes that is a lot of water.

Jason "Jake" McDougal
Program Manager-WVDEP-OER

On Jun 21, 2017, at 5:07 PM, pizarro, luis <pizarro.luis@epa.gov> wrote:

That's a lot of water, but PCB's are relatively insoluble in water, thus I am not surprise they have not had detection.

I'll check with the PCB people if there are any their regs covering this, but from my read of I could not see anything.

I'll get you something tomorrow.

Luis A. Pizarro
Associate Director
Office of Remediation, LCD
US EPA Region 3
215 814 3444

From: McDougal, Jason S [mailto:Jason.S.McDougal@wv.gov]
Sent: Wednesday, June 21, 2017 11:26 AM
To: pizarro, luis <pizarro.luis@epa.gov>
Subject: Momentive Water Treatment Upgrade

Luis,

John Garner has a question regarding GW that is infiltrating his excavation. They estimated 1000 GPH. They have sampled 3 times and all non-detect for PCBs.

John wants to know if they can:

1. Continue pumping the water and sampling in regular intervals. If detection occurs stop.
2. Contain in tank, test, then discharge
3. Have a contractor come in to test and handle the water.

Are there any regulations that would restrict how they handle the water?

Thanks

Jason (Jake) McDougal

Program Manager-CERCLA, DOD, RCRA CA, FUDS, Pre-CERCLA

WVDEP-Division of Land Restoration

Office of Environmental Remediation

601 57th Street SE

Charleston, WV 25304

304-926-0499 ext. 1130

Cell: 304-389-7596